



(1) EC-TYPE-EXAMINATION CERTIFICATE (Translation)

(2) Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres - **Directive 94/9/EC**



(3) EC-type-examination Certificate Number:

PTB 10 ATEX 2006

(4) Equipment: Explosion protected thermal release, type ExPro-TT-..

(5) Manufacturer: Schischek GmbH

(6) Address: Mühlsteig 45, 90579 Langenzenn, Germany

(7) This equipment and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.

(8) The Physikalisch-Technische Bundesanstalt, notified body No. 0102 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres, given in Annex II to the Directive.

The examination and test results are recorded in the confidential assessment and test report PTB Ex 10-29303 .

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 60079-0:2006

EN 60079-11:2007

EN 61241-0:2006

EN 61241-1:2004

EN 61241-11:2006

(10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.

(11) This EC-type-examination Certificate relates only to the design, examination and tests of the specified equipment in accordance to the Directive 94/9/EC. Further requirements of the Directive apply to the manufacturing process and supply of this equipment. These are not covered by this certificate.

(12) The marking of the equipment shall include the following:

II 2 G Ex ia IIC T6 or II 2 D Ex tD iaD A21 IP66 T80 °C

Zertifizierungssektor Explosionsschutz
By order:

Braunschweig, July 9, 2010

Dr.-Ing. U. Johannsmeyer
Direktor und Professor



(13)

SCHEDULE

(14)

EC-TYPE-EXAMINATION CERTIFICATE PTB 10 ATEX 2006

(15) Description of equipment

The explosion protected thermal release, type ExPro-TT-.. is used for the control of limit temperature ranges and for signal transmission.

The equipment is installed inside of hazardous locations.

For relationship between temperature class and maximum permissible ambient / medium temperature range, reference is made to the table:

Temperature class	Maximum permissible ambient / medium temperature range
T6	-40 °C ... 72 °C
T5	-40 °C ... 87 °C
T4	-40 °C ... 102 °C

Electrical data

Voltage supplytype of protection Intrinsic Safety Ex ia IIC
(terminals 1,2) or Ex ia D

only for connection to a certified intrinsically safe circuit

Maximum values:

$U_i = 30 \text{ V}$

$I_i = 22 \text{ mA}$

$P_i = 60 \text{ mW}$

L_i negligibly low

C_i negligibly low

(16) Assessment and test report PTB Ex 10-29303



(17) Special conditions for safe use

none

(18) Essential health and safety requirements

met by compliance with the standards mentioned above

Zertifizierungssektor Explosionschutz
By order:



Dr.-Ing. U. Johannsmeyer
Direktor und Professor

Braunschweig, July 9, 2010

1. SUPPLEMENT

according to Directive 94/9/EC Annex III.6

to EC-TYPE-EXAMINATION CERTIFICATE PTB 10 ATEX 2006

(Translation)

Equipment: Explosion protected thermal release, type ExPro-TT-..

Marking:  II 2 G Ex ia IIC T6 or II 2 D Ex tD iaD A21 IP66 T80 °C

Manufacturer: Schischek GmbH

Address: Mühlsteig 45, 90579 Langenzenn, Germany

Description of supplements and modifications

The explosion protected thermal release, type ExPro-TT-.. is used for the control of limit temperature ranges and for signal transmission.

The equipment is installed inside of hazardous locations.

Subject matter of this supplement is the revision and supplementation of the test documents for organizational reasons. The state of the standards is updated.

Further modifications have not been made.

The thermal and electrical data are represented in summary.

For relationship between temperature class and maximum permissible ambient / medium temperature range, reference is made to the table:

Temperature class	Maximum permissible ambient / medium temperature range
T6	-40 °C ... 72 °C
T5	-40 °C ... 87 °C
T4	-40 °C ... 102 °C

1. SUPPLEMENT TO EC-TYPE-EXAMINATION CERTIFICATE PTB 10 ATEX 2006

Electrical data

Voltage supply type of protection Intrinsic Safety Ex ia IIC
 (terminals 1.2) resp. Ex ia IIIC
 only for connection to a certified intrinsically
 safe circuit

Maximum values:

U_i = 30 V
 I_i = 22 mA
 P_i = 60 mW
 L_i negligibly low
 C_i negligibly low

The future marking reads:

 II 2 G Ex ia IIC T6 Gb or
 II 2 D Ex ia IIIC T6 Db or II 2 D Ex tb IIIC T80 °C Db IP66


Applied standards

EN 60079-0:2009 EN 60079-11:2012 EN 60079-31:2009

Test report: PTB Ex 13-23077

Zertifizierungssektor Explosionschutz
 On behalf of PTB:

Braunschweig, September 16, 2013



Dr.-Ing. U. Johannsmeyer
 Direktor und Professor

